

GOVERNMENT OF BIHAR
PUBLIC HEALTH ENGINEERING DEPARTMENT

SUB DIVISION: KHAGARIA MONTH: APRIL
2024

DISTRICT-KHAGARIA

SL	BLOCK	PANCHAYAT	VILL.	LOCATION	PARAMETERS										Remarks
1	GOGRI	MAHESHKHUNT	NA	DELAHI PUBLIC SCHOOL, MAHESHKHUNT	PH	EC	TDS	Fe	Alka	NO3	Turb	SO4			
					6.5-8.5	383	310	0.21	137	bdl	1	200			
					NR	-	533mg/lt	1.0mg/lt	200mg/lt	45	5	400			
					NR	-	2000mg/lt	NR	600mg/lt	NR	5	400			
					Desirable Limit										
					Permissible Limit * in absence of alternate source										

[Signature]
SUB DIVISIONAL CHEMIST
KHAGARIA

[Signature]
SDO
SUB DIVISION KHAGARIA